

**APPLICATION FOR PERMIT TO APPROPRIATE THE PUBLIC
WATERS OF THE STATE OF NEVADA**

Date of filing in State Engineer's Office MAY 06 2005

Returned to applicant for correction _____

Corrected application filed _____

Map filed MAY 06 2005

The applicant **John L. Collett and Janice H. Collett, trustees of Collett Family Trust** hereby make application for permission to appropriate the public waters of the State of Nevada, as hereinafter stated.

1. The source of the proposed appropriation is **Underground**
2. The amount of water applied for is **0.10 cfs** second-feet
 - (a) If stored in reservoir give number of acre-feet
3. The water to be used for **Quasi-Municipal purposes**
4. If use is for:
 - (a) Irrigation, state number of acres to be irrigated
 - (b) Stockwater, state number and kinds of animals to be watered
 - (c) Other use (describe fully under No. 12. "Remarks")
 - (d) Power:
 - (1) Horsepower developed
 - (2) Point of return of water to stream
5. The water is to be diverted from its source at the following point **SW $\frac{1}{4}$ SW $\frac{1}{4}$ of Section 34, T.34N., R.56E., M.D.B.&M., at a point from which the South $\frac{1}{4}$ corner of said Section 34, bears S 56° 25' 05" E, 1870.12 feet.**
6. Place of Use **Portions of SW $\frac{1}{4}$ SW $\frac{1}{4}$, SE $\frac{1}{4}$ SW $\frac{1}{4}$ of Section 34, T.34N., R.56E., M.D.B.&M., being Parcels No. 1-A, 1-B, 2-A and 2-B per Parcel Map for John L. Collett and Janice H. Collett, trustees of Collett Family Trust, File No. 530846, Elko County, Nevada, Official Records.**
7. Use will begin about **January 1** and end about **December 31** of each year.
8. Description of proposed works **Well and pipe lines**
9. Estimated cost of works **\$10,000.00**
10. Estimated time required to construct works **3 years**
11. Estimated time required to complete the application of water to beneficial use **5 years**

12. Remarks: This application is to serve 4 single family residences.

High Desert Engineering
By s/ Robert E. Morley
Robert E. Morley, Agent
640 Idaho Street
Elko, Nevada 89801

Compared aem/sam dl/gkl

Protested _____

APPROVAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit is issued subject to existing rights. It is understood that the amount of water herein granted is only a temporary allowance and that the final water right obtained under this permit will be dependent upon the amount of water actually placed to beneficial use. It is also understood that this right must allow for a reasonable lowering of the static water level. This well shall be equipped with a two (2) inch opening for measuring depth to water. If the well is flowing, a valve must be installed and maintained to prevent waste. A totalizing meter must be installed and maintained in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to beneficial use. The totalizing meter must be installed before any use of water begins, or before the Proof of Completion of Work is filed. This source is located within an area designated by the State Engineer, pursuant to NRS 534.030. The State retains the right to regulate the use of the water herein granted at any and all times.

This permit does not extend the permittee the right of ingress and egress on public, private or corporate lands.

The issuance of this permit does not waive the requirements that the permit holder obtain other permits from State, Federal and local agencies.

This permit is issued under the provisions of NRS 534.120(2) as a preferred use.

Monthly records shall be kept of the amount of water pumped from this well and the records submitted to the State Engineer on February 15th of each year.

This permit is being issued to service four (4) single family dwellings. Each dwelling shall be limited to 1000 gallons per day (1.12 acre-feet annually) and the total amount pumped from this well shall not exceed an annual duty of 4.48 acre-feet.

Any water not put to beneficial use under this permit will return to the groundwater source and not be subject to any further transfers.

(CONTINUED ON PAGE 3)

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, and not to exceed 0.10 cubic feet per second, not to exceed 4.48 acre-feet.

Work must be prosecuted with reasonable diligence and be completed on or before:

March 6, 2007

Proof of completion of work shall be filed on or before:

April 6, 2007

Water must be placed to beneficial use on or before:

March 6, 2010

Proof of the application of water to beneficial use shall be filed on or before:

April 6, 2010

Map in support of proof of beneficial use shall be filed on or before:

N/A

IN TESTIMONY WHEREOF, I, HUGH RICCI, P.E.,

State Engineer of Nevada, have hereunto set

my hand and the seal of my office,

this 6th day of March, A.D. 2006


State Engineer

Completion of work filed APR 20 2007

Proof of beneficial use filed _____

Cultural map filed _____ N/A

Certificate No. _____ Issued _____